

Used 30,000 Gallon Storage Vessel

**Available for Immediate Delivery
LPG/NGL Service**

This tank is located in Rocky Mount, NC

If we do not have a new or used tank or set of matching storage vessels in inventory to suit your needs, we will gladly locate the tanks you need at a competitive price, or we can custom manufacture the tank or set of vessels you require—to your exact specifications.

Year	MFG	Capacity	PSI	Serial No. / National Board No.	U1A Data Report
1974	Mississippi Tank Co.	30,000	250	76345 / 6607	Available



FORM U-1A MANUFACTURERS' DATA REPORT FOR PRESSURE VESSELS
Alternate Form for Single Chamber C. Specially Shop-Fabricated Vessels Only
As Required by the Provisions of the ASME Code Rules, Section VIII, Division I

1. Manufactured by MISSISSIPPI TANK CO., INC. HATTIESBURG, MISS.

2. Manufactured for Foxco, Inc., Winchester, KY P.O. #F530

3. Type Horiz. Vessel No. 79345 (Date Month) (Year & Week No.) Natl. Bd. No. 6607 Yr. Built 1974

4. SHELL: Matl. SA515-70 (Kind and Spec. No.) Thick. 1.5 (Fig. or P.R. & Spec. Mfg. T.P.) In. Allow. 0 In. Diam. 9 Ft. 6 In. Length 51 Ft. 7 In. S/S

5. SEAMS: Long. Butt H.T. No R.T. Comp. Sectioned No Efficiency 100 %
Circ. Dist. Single Lap Butt No (Type or Spec.) (Type or Spec.) (Type or Spec.)
Circ. Single H.T. No R.T. Comp. Sectioned No No. of Courses 6

6. HEADS: (a) Material SA455-B T.S. 73,000 (b) Material SA515-70 T.S. 30,000
Crown (Top, Bottom, Ends) Thickness 1.5 Radius 56.375 (c) Material SA515-70 T.S. 30,000
(a) Ends 458 (b) Material SA515-70 T.S. 30,000
(c) Material SA515-70 T.S. 30,000
Other facing: Concave

7. Constructed for max. allowable working press. 250 psi at max. temp. 650 °F. Min. temp. (when less than -10°) 0 °F. Hydrostatic Test 375 psi.

8. SAFETY OR RELIEF VALVE OUTLETS: Number 3 Size 2" Location Top of Shell

9. NOZZLES:

Number	Type	Material	Thickness	Rating	How Attached
Relief Va.	3	2"	Colg.	SA105 3000#	Inherent Welded
	1	2"	Flg.	SA515-70 1.5"	Inherent Welded
	1	1"	Colg.	SA105 3000#	Inherent Welded
	7	2"	Colg.	SA105 3000#	Inherent Welded
	1	3/4"	Colg.	SA105 6000#	Inherent Welded
	1	4"	T.W.	SA105 3000#	Inherent Welded

10. INSPECTION: Manholes, No. _____ Size _____ Location _____
OPENINGS: Handholes, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

11. SUPPORTS: Skin No Lugs (Number) _____ Legs (Number) _____ Other (Describe) _____ Attached (Where & How) _____

12. REMARKS: 30,000 W.G. Capacity LPG Storage Tank
114 3/8" O.D. x 61' - 2" O.A.L.
Seams are dbl. butt welded and spot x-rayed.

* Per Para. UW-11 (a)(5)(b)
Brief description of purpose of the vessel in Air Tank, Water Tank, L.P.G. etc. - State Contents.
If provided, list other internal or external pressures with coinciding temperature when applicable.
By signing this statement made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division I.
Date 6-17-1974 Signed Mississippi Tank Co., Inc. By William L. Halligan, P.E.
Certificate of Authorization Expires DECEMBER 31, 1976

Need help with your project? Save time and money, TransTech can provide Valve & Instrumentation kit to fit your tank, freight to the project site and full installation. Feel comfortable your project will be installed to the latest NFPA 58 Standard and will fit your needs.

Tank Set & Installation! From providing expert engineering assistance in specifying the correct valve and instrumentation, size piers to coordination of freight and offloading - through to site excavation and tank set, we provide a turnkey bulk plant or terminal solution.



TransTech Energy LLC - Tel: (+1)888-206-4563
www.transtechenergy.com

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY MISSISSIPPI TANK COMPANY, INC., HATTIESBURG, MISSISSIPPI

I, the undersigned, holder of a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province _____ and employed by THE STATE of MISSISSIPPI have inspected the pressure vessel described in the manufacturer's data report on 6-17-1974 and certify that to the best of my knowledge and belief, the manufacturer has constructed this pressure vessel in accordance with the applicable sections of the ASME Boiler and Pressure Vessel Code.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 6-17-1974 National Board No. 2753
Inspector's Signature William L. Halligan Commission Penn W.C. Ark. No. _____
Natl. Board, State, or Province and No. _____