

Used 30,000 Gallon Storage Vessel

**Available for Immediate Delivery
LPG/NGL Service**

This tank is located in Rocky Mount, NC

If we do not have a new or used tank or set of matching storage vessels in inventory to suit your needs, we will gladly locate the tanks you need at a competitive price, or we can custom manufacture the tank or set of vessels you require—to your exact specifications.

Year	MFG	Capacity	PSI	Serial No. / National Board No.	U1A Data Report
1951	Bethlehem Steel	30,000	U69-200	1694 / 1262	Available



Need help with your project? Save time and money, TransTech can provide Valve & Instrumentation kit to fit your tank, freight to the project site and full installation. Feel comfortable your project will be installed to the latest NFPA 58 Standard and will fit your needs.

Tank Set & Installation! From providing expert engineering assistance in specifying the correct valve and instrumentation, size piers to coordination of freight and offloading - through to site excavation and tank set, we provide a turnkey bulk plant or terminal solution.



TransTech Energy LLC - Tel: (+1)888-206-4563
www.transtechenergy.com

BSCo. 027173 (41) For Warren Petroleum Corp.
FORM U-1 MANUFACTURERS' DATA REPORT FOR UNFIRED PRESSURE VESSELS

As Required by the Provisions of the A.S.M.E. Code Rules

- Manufactured by Bethlehem Steel Company, Bethlehem, Penna.
(Name and address of the manufacturer)
 - Manufactured for Dwane Gas & Appliance Co., Elizabethtown, North Carolina
(Name and address of the purchaser)
 - Type Horizontal Unfired Pressure Vessel No. (BSCo. 1694) (N. B. 1262) Year built 1951
(Horizontal or Vertical) (Mfr.'s serial, or A.S.M.E. No.) (State and State No.) Dr. 1-3717
 - Have mill test reports been checked on all the plates entering this unfired pressure vessel. Yes
Do the chemical and physical properties of all plates meet the requirements of the Code. Yes
 - Shell or Drums: No. 2 Diameter 8 ft. 10 in. Length over-all 67 ft. 1/2 in. Height 8 ft. 7 in.
(or width)
 - Stamps on shell plates A212, 70000 Grade B FBr. Bolts & Studs A193 Gr. E7 Nuts A194 Cl. 2
(Brand and Lowest Tensile Strength) Riveted/Double-Butt (Iron or steel) Double-Butt
 - Shell Plates 0.76 in. Butt straps 0.76 in. Style of seams: Longitudinal Fusion Welded Girth Fusion Welded
(Outer Thickness) (Thickness) (Riveted, Forge Welded, Braised, or Fusion Welded—Par. No.)
 - Diameter of rivet holes 0.76 in. Pitch of rivets X Efficiency of joint 80 %
 - Girth Joints 0.76 in. Diameter rivet holes 0.76 in. Pitch of rivets X No. of courses 7
(Single or double riveted)
 - Lower Shell 0.76 in. Style of seams: Longitudinal Girth Length of section or course 8 ft. 7 in.
(Thickness) (Riveted, Forge Welded, Braised, or Fusion Welded—Par. No.)
 - Heads: Flat or dished 0.76 in. Radius of dish 11 in. Side to pressure Concave
(Thickness) (Concave or convex)
- If removable, bolts used 0 or method of fastening None
(Number and size) (Describe or sketch)

STAYS	No.	Size	Net Area	Welded or Riveted		Maximum Allowable Working Pressure
				Welded or Riveted	Area to be Stayed	
12. (a) F. H.						
(b) R. H.						
(c) Through						
(d) Diagonal and Gusset Stays						

RECEIVED
 AUG 16 1951
 THE NATIONAL BOARD OF BOILER & PRESSURE VESSEL INSPECTORS

- STAY BOLTS: If hollow 0 14. Maximum pitch 32" in.
(Iron or Steel) (Size of hole) (Horizontal) (Vertical) (Diameter of the threads)
- SAFETY VALVE outlets: No. 1 Size 1"
- FUELS PLUG (if used): No. 1 Diameter and material of filling 01023 Steel Location Welded
(Riveted, Welded, etc.)
- OUTLETS: No. 1 Size 1" Material of nozzle or reinforcement 01023 Steel How attached Welded
(Riveted, Welded, etc.)
- DRAIN CONNECTION: 2 in. HAND HOLES OR SCOUR HOLES 0
(Size) (Number, size, and location)
- MANHOLES: 1 18" ID. In Shell Reinforcement 32" 0.96" Thk. Welded Pad
(Number) (Size and location of each) (Riveted, Welded, etc.)
- NONPRESSURE PARTS: (a) Supporting lugs 0 Supporting skirts 0 (b) Other nonpressure parts Shipping Lugs, Platform Clips, Ladder Clips
(Number) (Kind and number)
- Where and how attached Welded
- Working pressure 1002 psi Hydrostatic test 400 lb 22. Constructed for pressure of 250 psi Factor of safety 4

Remarks: Vessel To Be Used For Propane Storage; 30,000 Gal. Capacity. Construction In
(Vessel to be used for air, gas, ammonia, etc.)

Accordance With ASME 1950 Code; Also complies With U-69 At 200 psi WP.

Certificate Of Authorization Expires December 31, 1952

We certify the above data to be correct and that all details of material, construction, and workmanship on this unfired pressure vessel conform to the A.S.M.E. Code for Unfired Pressure Vessels.

Date Jan 15 19 51 Signed Bethlehem Steel Company
(Manufacturer)

[Signature]
 O. H. Johnson