

Used 12,000 Gallon Storage Vessel

**Available for Immediate Delivery
LPG/NGL Service**

This tank is located in Rocky Mount, NC

If we do not have a new or used tank or set of matching storage vessels in inventory to suit your needs, we will gladly locate the tanks you need at a competitive price, or we can custom manufacture the tank or set of vessels you require—to your exact specifications.

Year	MFG	Capacity	PSI	Serial No. / National Board No.	U1A Data Report
1979	Mississippi	12,000	250	80654 / 7697	Available



FORM U-1A MANUFACTURERS' DATA REPORT FOR PRESSURE VESSELS
(Alternate Form for Single Chamber, Completely Shop-Fabricated Vessels Only)
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured by MISSISSIPPI TANK CO., INC. Hattiesburg, MS
 2. Manufactured for ARCO OIL COMPANY Atlanta, GA
 3. Location of installation Montezuma, GA
 4. Type DRUM No. 80654 Code CS-1 Year Built 7697 (Year Built) 1979

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER and PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1, 1979, and Addenda to 1979, and Code Case Nos. _____

Special Service per UG-120(d)
 Manufacturers' Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished the following items of the report:

6. Shell: Matl. SA455 Thk. .5625 in. Allow. 0 in. Diam 82 9/16 Lgth. 39 ft. 10 in. SM/SM
 7. Seams: Long. DBL. BUTT R.T. FULL Efficiency 100 % H.T. Temp. NONE F Time hr.
 Girth DBL. BUTT (CLDSING - SINGLE W/PACKING) R.T. PARTIAL No. of Courses 4
 8. Heads: (a) Material SA455 (b) Material _____

Location (Top, Bottom, End)	Size	Con. Angle	Reinforcement	How Attached	Location
(a) <u>ENDS</u>	<u>32 3/4</u> "	<u>0</u> "		<u>41.281</u> " OR <u>CONCAVE</u>	

(b) _____

If removable, bolts used (described other fastenings) _____

9. Constructed for max. allowable working pressure 250 psi at max. temp. 650 °F Min. temp. (when less than -20 F) _____ F. Hydrostatic test pressure 375 psi.

10. Safety Valve Outlets: Number 2 Size 2" Location TOP OF VESSEL

11. Nozzles and Inspection Openings:

Purpose (Inlet, Outlet, Drain)	No.	Size	Type	Matl.	Thk.	Reinforcement	How Attached	Location
<u>SCHEP</u>	<u>2</u>	<u>2</u> "	<u>CPG.</u>	<u>SA105</u>	<u>3000#</u>	<u>INHERENT</u>	<u>WELDED</u>	
<u>PRESS. GA.</u>	<u>1</u>	<u>1 7/8</u> "	<u>CPG.</u>	<u>SA105</u>	<u>6000#</u>	<u>INHERENT</u>	<u>WELDED</u>	
<u>OUT. GA.</u>	<u>1</u>	<u>1 7/8</u> "	<u>CPG.</u>	<u>SA105</u>	<u>6000#</u>	<u>INHERENT</u>	<u>WELDED</u>	
<u>POINT GA.</u>	<u>1</u>	<u>2 1/2</u> "	<u>CPG.</u>	<u>SA105</u>	<u>3000#</u>	<u>INHERENT</u>	<u>WELDED</u>	
<u>TEMP. IND.</u>	<u>1</u>	<u>1 7/8</u> "	<u>R.W.</u>	<u>SA105</u>	<u>3000#</u>	<u>INHERENT</u>	<u>WELDED</u>	
<u>L. LIQUID</u>	<u>1</u>	<u>2</u> "	<u>CPG.</u>	<u>SA105</u>	<u>6000#</u>	<u>INHERENT</u>	<u>WELDED</u>	
<u>PLUG</u>	<u>1</u>	<u>2</u> "	<u>CPG.</u>	<u>SA105</u>	<u>3000#</u>	<u>INHERENT</u>	<u>WELDED</u>	

SEE SUPPLEMENTAL SHEET ATTACHED

12. Supports: Skirt NO Lugs _____ Legs _____ Other _____ Attached _____

13. Remarks: 12,000 W.G. CAPACITY PROPANE STORAGE TANK. 82 9/16" O.D. X 46'-9" O.A.L.
HEAD GORE SEAMS ARE DBL. BUTT WELDED AND SPOT RADIOGRAPHED.
VESSEL IS DESIGNED FOR NON CORROSIVE SERVICE.

CERTIFICATE OF COMPLIANCE
 We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.
 Date 8/13/79 signed James F. Hollingsworth
 "U" Certificate of Authorization No. 236 expires December 31, 19 79

CERTIFICATE OF SHOP INSPECTION
 Vessel made by MISSISSIPPI TANK CO., INC. at Hattiesburg, MS
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of MS and employed by H.S.B. & CO. have inspected the pressure vessel described in this Manufacturer's Data Report on 8/13/79 and state that to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Signed J. A. Jones Date 8/13/79 Commission NR5804 MS47

Need help with your project? Save time and money, TransTech can provide Valve & Instrumentation kit to fit your tank, freight to the project site and full installation. Feel comfortable your project will be installed to the latest NFPA 58 Standard and will fit your needs.

Tank Set & Installation! From providing expert engineering assistance in specifying the correct valve and instrumentation, size piers to coordination of freight and offloading - through to site excavation and tank set, we provide a turnkey bulk plant or terminal solution.



